



Style 10678 - APPLIANCE WIRING MATERIAL

APPLIANCE WIRING MATERIAL

Subj.758
Section 1
Page 10678

Issued: 2003-05-28
Revised: 2011-09-16

Style 10678 Single conductor with extruded insulation and jacket

RATING 90 deg C, 1000 Vac, Horizontal flame, Cable flame.

CONDUCTOR 32 AWG minimum. Solid or stranded.

INSULATION Labeled or complying with manufacturer's AWM procedure.

COVERING Optional.

SHIELD Optional.

JACKET Extruded PVC

Diameter of core assembly under jacket	minimum average thickness	minimum thickness at any point
0.700 inch or less	30 mils	24 mils
0.701-1.000 inch	45 mils	36 mils
1.001 - 1.500 inch	60mils	48 mils
1.501 - 2.500 inch	80 mils	64 mils

STANDARD Appliance Wiring Material UL 758.

MARKING General.

USE External Wiring

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"